



CONSTRUCTION UPDATES & ACTIVITIES

Week Ending December 9, 2022

5200/6100 Switchgear Project

Work this week: Contractor poured concrete slab. However, core samples revealed inadequate grout penetration of block cells. Contractor has been instructed by structural engineer to demo a portion of the north facing wall.

Noise: Loud noise from equipment & trucking
Parking: Work vehicles will be parking in designated areas listed on the construction alert.

Utilities: No Interruptions at this time.
Odors: None

