



**CONSTRUCTION UPDATES & ACTIVITIES**

*Week Ending December 9, 2022*

**COE Fiber Run**

**Work this week:** Contractor pulled fiber to COE Teleplex building. During patch in, it was discovered that an existing patch cable has failed. Taft Electric has made a temporary fix and will order a new patch cable. Please note that work related to diagnosing and fixing patch cable is out of scope.

- Noise:** Loud noise from equipment & trucking
- Parking:** Work vehicles will be parking in designated areas listed on the construction alert.
- Utilities:** No Interruptions at this time.
- Odors:** None

